

**BUSINESS FOR THE CITY COUNCIL  
OF THE  
CITY OF ANGLETON**

---

---

**SUBJECT:**

WWTP 1 Level and / or Replace Weirs; Replace telescoping valves and relocate Weir 3 RAS

SUBMITTED BY: Herbert S. Smith, P.E.

DATE SUBMITTED: 20 August 2008 FOR THE AGENDA OF: 26 August 2008

Expenditure Required: \$120,607.36 MM Construction  
\$ 4,000 BLI for Inspection  
\$124,607.36 Total

Available Funding: \$124,607.36

Attachments: Letter of Recommendation

---

---

**SUMMARY STATEMENT:**

This project was originally authorized with a budget from Lockwood, Andrews and Newman 2006 Study of the plant (\$42,000). However the firm appears to have underestimated the effort required for leveling. There is the potential for \$27,000 reduction in price if a portion of the existing weirs can be replaced.

Telescoping valves and relocation of RAS (to the design location, US Filter relocated it during their operation) are required to allow for the draining of the clarifiers and leveling to proceed. These operations were recommended in the LAN report.

Leveling of the weirs is required by TCEQ.

Because the Blowers, and now this project, have substantially exceeded the budget established by LAN we have ceased work on the WWTP plant upgrade authorized by Council in 2007. We recommend that the individual components of the report be addressed as cash flow allows.

=====  
**Recommendation: Approve Project**