

BUSINESS FOR THE CITY COUNCIL
OF THE
CITY OF ANGLETON

SUBJECT:

Discussions on Outdoor Pool Renovation/ Relocation

REQUESTED BY: Chris Orlea

SUBMITTED BY: Chris Saddler

DATE SUBMITTED: 1/5/09

FOR THE AGENDA OF: 1/13/09

Expenditure Required: Estimated \$150,000.00

Available Funding: n/a

Attachments: Quotes for salt chlorination system, new pool construction, and fencing quotes. Revenue report.

SUMMARY STATEMENT:

The outdoor pool located on the South side of town, built in 1948, is currently in need of major repairs. Because of corroding lines, air entered our pump system and has cavitated the pump, a replacement cost of \$6,500.00 + s&h and installation. Also, within this time line the Virginia Graeme Baker Act has been implemented requiring us to install a Safety Vacuum Release System at a cost of \$1,000 + s&h and installation. The pool is also lifting from the ground due to an unknown instability causing the shell to rise up to 3" in some places

Recommendation: This is a discussion item only. This is an agenda item at the parks board meeting on Monday for their thoughts. Staff thoughts are to convert the current outdoor pool site into a south side park, per our master plan, and reconstruct the pool on current recreation center property to accommodate higher level swim lessons, and lifeguard training; something that the depth of our current pool prohibits. With the increasing price of chlorine in mind, the new pool would be equipped with a salt system to match the current recreation center setup.