



CITY OF FARMINGTON
Department of Public Works
101 South Jefferson Street
Farmington, Missouri 63640
573.756.0608

Virginia, Yale, Wesley Aldergate and Hew Street Water Main Replacements

ADDENDUM #1

Date: 1/22/2025

This Addendum forms a part of the Bidding and Contract Documents and modifies the original Bidding Documents.

FAILURE TO ACKNOWLEDGE RECIEPT OF ADDENDUM MAY SUBJECT BIDDER TO DISQUALIFICATION.

CURB REPLACEMENT CLARIFICATION

A bidder asked a question about our intentions regarding curb & gutter replacement: It is our intention that the curb and gutter would only need to be replaced in locations where the main or service line crosses the curb line. Furthermore, it is our assumption that the contractor will not need to replace the curb and gutter for the areas where the water main runs parallel to the curb.

Additional information: it is our assumption that the contractor will only need to saw-cut the street-side of the trench and remove the existing asphalt from the saw-cut line to the face of the gutter pan.

Additional Information: The City of Farmington has a service Line Puller tool that is available for the contractor to use to replace the service lines. The City of Farmington has had success using this tool to replace service lines previously.

END OF ADDENDUM NO. 1