

**Adoption of the National Electrical Code. The minimum electrical wiring standard shall be the 2011 National Electrical Code, National Fire Protection Association Publication Number 70-2008, is hereby adopted as amended, altered, modified and changed in the following respects:**

**Add Article 90.10 Application.** All applications shall be submitted by either an “Electric Contractor” Or “Class A Master” licensed by the Nebraska State Electrical Board, or the owner of the home that is presently residing in the single-family dwelling that will install and connect the electrical wiring him or herself without compensation or pay from, or to, any other person.

**Article 210.8 Ground-Fault Circuit-Interrupter Protection for Personnel.** Add at the end of this section: Lighting where installed in combination with GFCI’s shall be upstream or in front of the GFCI protection. Preventing the loss of lighting in the event a GFCI is tripped.

**Article 210.52(D) Bathrooms.** Add at the end of this section: If apparent work space is adjacent to a sink, the required outlet shall be installed on the side of the sink basin nearest the work station.

**Article 250.52(A)(3) Concrete-Encased Electrode.** Add at the end of this section: All new buildings or structures, and any new addition to buildings or structures when adding a foundation shall require a concrete encased electrode.

**Article 314.27(C) Boxes at Ceiling-Suspended (Paddle) Fan Outlets.** Add at the end of this section: In all dwelling units, boxes installed in bedroom ceilings for light fixtures shall be fan rated. In other areas of the dwelling where fans are to be installed, fan rated boxes shall be used.

**Article 334.10(5)(A)(1) Type NM.** Delete in its entirety and reword as follows: For both exposed over 8’ in height and concealed work in normally dry locations except as prohibited in 334.10(3).

**Article 334.10(5)(B)(1) Type NMC.** Delete in its entirety and reword as follows: For both exposed over 8’ in height and concealed work in dry, moist, damp, or corrosive locations, except as prohibited in 334.10(3).

**Article 334.10(5)(C)(1) Type NMS.** Delete in its entirety and reword as follows: For both exposed over 8’ in height and concealed work in normally dry locations except as prohibited in 334.10(3).