

*W*INTER HAVEN

The Chain of Lakes City

August 13, 2010

Addendum 3

ITB-10-56

The Invitation to Bid, ITB-10-56, Chain Of Lakes Achievers HVAC System Replacement, is hereby changed by the following:

The following comments and clarifications are provided in response to questions asked regarding Invitation to Bid, ITB-10-56, The Chain of Lakes Achievers HVAC System Replacement:

1. Any holes made in the ceiling by the contractor will be patched by the contractor.
2. Any existing HVAC units, with the exception of the wall mount unit, removed will become the property of the contractor, to be disposed of off-site. They will not be returned to the City.
3. The existing wall mount unit will be removed and returned to the City.
4. Replace any existing copper tubing with new copper tubing.
5. Load calculations will be done after award of bid to the contractor and are not a part of the bid package.
6. The bid submitted should be based on using existing ductwork.

All other terms and conditions remain the same.

Sincerely,

CITY OF WINTER HAVEN



Bob Bishop

Procurement Services Division Director