

WINTER HAVEN

The Chain of Lakes City

October 4, 2010

**ADDENDUM #2
ITB-10-57
Magnolia Water Tower Painting Project**

The Invitation To Bid for the Magnolia Water Tower Painting Project, (ITB-10-57) is hereby amended by this Addendum Number Two by correction of the following:

1. Under "BONDING COMPANY'S QUALIFICATIONS": change the Financial Size Category requirement to "VII"
2. Existing height of Balcony railing is 36", current OSHA Regulation and specification height is 42" as per the bid documents.
3. Selected bidder is to commence work within 45 days of issue of letter to proceed.
4. Selected bidder will be responsible for disconnection, removal prior to painting, and upon completion re-installation of interior cathartic Protection system.
5. Selected bidder will be responsible for evaluating existing tank electrical system and remove all unnecessary components (including but not limited to) enclosures, wiring conduits that are not required for the operation of the tanks aviation warning light and cathartic protection system. All components disturbed shall be coated and painted to match existing tank coating color.
6. All electrical enclosures that are required as part of the operation of the tanks aviation warning light and cathartic protection system shall be replaced using Type NEMA 4X 304 or 316L Stainless Continuous-Hinge door with clamps enclosures Junction Boxes. Boxes will be a minimum 6 inches in depth. Shall be manufactured by Hoffman Enclosure Inc. or equal. All replaced conduit and fittings to be galvanized coated and painted to matched existing tank coating color. All wiring replaced shall be new and the type and size to meet NEC electrical codes with #12 being the minimum size.
7. Bidder is responsible for field verifying all items (including but not limited to) dimensions, electrical, materials, etc. required to complete all aspects of this bid.

All other terms and conditions remain the same.

Sincerely,

CITY OF WINTER HAVEN



Bob Bishop
Procurement Services Division