

*W***INTER HAVEN**

The Chain of Lakes City

December 8, 2010

Addendum 2

ITB-11-12

The Invitation To Bid – Hydropneumatic Tanks is hereby changed by the following:

Clarification to Part 2 Hydro pneumatic tank details are as follows:

1. Tanks are built to ASME specifications and are not NB (National Board Stamp) or registered with the National Board. The data plate on the vessels are design data only.
2. A certification statement by the manufacturer of the tanks certifying that the tanks were built to ASME specifications and designed for 150 psig @ 100 degrees F is required.

All other terms and conditions remain the same.

Sincerely,

CITY OF WINTER HAVEN



Bob Bishop

Procurement Services Division Director