



June 24, 2011

Addendum 1

ITB-11-57

The Invitation To Bid – Q-Block/Sidewalk Trail, ITB-11-57, is hereby changed by addition of the following:

Question 1: There are several large trees in the path of the proposed sidewalks. Is the Contractor to be responsible for the removal and disposal of these trees?

NO, BUT THERE MIGHT BE A NEED TO DO SOME MINIMAL ROOT GRINDING

Question 2: There are several chain link fences in the path of the proposed sidewalks. Is the Contractor to be responsible for the removal, disposal and/or replacement of the fencing?

NO. THE SIDEWALK IS TO BE CONSTRUCTED NEXT TO THE FENCES.

Question 3: There is a deep drainage ditch at the intersection of Quintin Avenue and Unity Way. Is the Contractor responsible for adding fill dirt to accommodate the proposed sidewalk?

YES, JUST ENOUGH TO ACCOMMODATE A 4 FT WIDE, RAISED SIDEWALK.

Question 4: There are no elevations indicated on the drawings. Should the Contractor follow the existing grades for the proposed sidewalks?

YES, EXCEPT FOR THE LOCATIONS WHERE A 6" RAISED SIDEWALK IS REQUIRED.

Question 5: Are there any permits required for the construction of the proposed sidewalks required for the Contractor to pull? If so, how many and at what cost?

NO PERMITS REQUIRED. M.O.T. SET UP IS REQUIRED PER THE APPROPRIATE FDOT 600 SERIES.

Question 6: At the pre-bid conference it was stated that no concrete testing would be required, but compaction testing would be required. Will the City be performing these tests or will it be the Contractor's responsibility. If so, at what spacing?

COMPACTION TESTING IS THE CONTRACTOR'S RESPONSIBILITY. 400 FT INTERVALS WITH A MINIMUM OF ONE TEST PER BLOCK. REFER TO NOTE 3 ON SHEET 5.

Question 7: Is the City tax-exempt for state sales tax or will the Contractor be responsible for the payment of the sales tax?

CONTRACTOR MUST INCLUDE SALES TAX IN THE BID PRICE FOR ALL ITEMS CONTRACTOR PURCHASES

Question 8: Are there any existing utilities in the path of the proposed sidewalks that possibly could be damaged by the new construction?

THERE ARE EXISTING UTILITIES IN THE PATH OF THE PROPOSED SIDEWALK. IT IS THE CONTRACTOR'S RESPONSIBILITY TO PROTECT AND PREVENT ANY DAMAGE TO ALL EXISTING UTILITIES.

Question 9: Have the tenants in the path of the proposed sidewalk construction been notified of the construction of the sidewalks?

NO, THE CITY WILL NOTIFY AREA RESIDENTS PRIOR TO PROJECT STARTING.

Question 10: What is the Engineer estimate for this project?

THE PROJECT ESTIMATED COST IS \$38,800.00

All other terms and conditions remain the same.

Sincerely,

CITY OF WINTER HAVEN

A handwritten signature in cursive script, appearing to read "Judie Serode".

Judie Serode

Procurement Services Division