

# WINTER HAVEN

*The Chain of Lakes City*

January 18, 2012

Addendum 1

ITB-12-23

The Invitation To Bid – Sanitary Sewer Pipe Rehab, ITB-12-23, is hereby changed by clarification of the following:

Q.) Does the above mentioned project have specified completion times or liquidated damages?

Q.) Questions concerning project ITB 12-23. What is the liquidating damages? Contract calendar days?

**A.) There are no liquidating damages referenced in the contract, and regarding contract calendar days, this would be 180 calendar days.**

Q.) Can you specify what the city is looking for with the hammer taps?

**A.) Hammer taps are existing and protruding laterals and will need to be cut or ground prior to lining, and service reinstated after lining.**

All other terms and conditions remain the same.

Sincerely,

CITY OF WINTER HAVEN



Judie Serode  
Procurement Services Division