

# REQUEST FOR QUOTATION

CITY OF WINTER HAVEN

" An Equal Opportunity Employer"

RFQ-10-71 \_\_\_\_\_

Please return quote to:  
 City of Winter Haven  
 Procurement Service Division  
 P.O. Box 2277  
 Winter Haven, FL 33883-2277

For additional information and clarification contact:

\* Department Name: Central Stores  
 \*Contact Person: Larry/Bob  
 \*Telephone #: (863) 291-5664

**DATE ISSUED:**

10-Sep-10

Please quote on the following items:

Item*	Quantity*	Description*	Unit Cost	Total Cost
A	3	36" Mueller/Kennedy Fire Hydrant	\$ _____	\$ _____
B	2	48" Mueller/Kennedy Fire Hydrant	\$ _____	\$ _____
Total				\$ _____
<b>Please see attached specification sheet</b>				

\* To be filled out by dept.

**Prices must be valid for 90 days.**

Procurement Services Division Director:

DELIVERY WANTED: Within 5 days ARO

We offer to sell you as above F.O.B., Winter Haven, Florida. Delivery can be made in \_\_\_\_\_ days from receipt of order.

Date: \_\_\_\_\_ Return this quotation NOT LATER THAN 2:00 P.M., Sept 21, 2010

TO: Procurement Services Division, address above or FAX TO 863-291-5666

SIGNATURE: \_\_\_\_\_

\*\*COMPANY NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE: \_\_\_\_\_

PHONE: \_\_\_\_\_

FAX: \_\_\_\_\_

**W-9 MUST BE ATTACHED TO THE RFQ WHEN RETURNED BY THE RESPONDING VENDOR.**

**\*\*PAYMENT WILL BE RENDERED TO THE NAME AND ID APPEARING ON THE W-9.**

Form MUL for purpose of Form 12022009 (5) Hydrants Kennedy Mueller

Fire hydrants shall be domestic such that all it conforms to the standard unit measurement not metric unit measurements. Fire hydrants shall have 5 1/4 inch valve opening and shall comply with AWWA Standard C502 for fire hydrants for water works service, unless in conflict with MANUAL in which case this manual shall apply. Each hydrant shall have 6-inch mechanical joint ends with harnessing lugs (dog-ears") and shall open by turning to the left (counterclockwise). Fire hydrant shall be of ample length for 3 foot depth of bury. It shall be provided with two 2-1/2-inch hose nozzles and one 4-1/2-inch pumper nozzle, all having National Standard hose threads. Nozzles shall have caps attached by chains. Operating nuts shall be AWWA Standard (pentagonal, measuring 1-1/2-inch point to flat). Fire hydrants shall be equipped with "O-Ring" packing.