



April 11, 2011

Addendum 1

RFQ-11-46

The Request For Quotation – 10” C900 Pipe and 10” HDPE Pipe for St Lucie Road, RFQ-11-46, is hereby changed by clarification of the following:

1. Replace Specification page with the attached Specification Page A-1 (brand requirements have been deleted).

All other terms and conditions remain the same.

Sincerely,

CITY OF WINTER HAVEN

A handwritten signature in cursive script, appearing to read 'Bob Bishop', is written over a large, faint circular watermark of the City of Winter Haven seal.

Bob Bishop

Procurement Services Division Director

## SPECIFICATIONS

PVC potable water main pipe 4" through 12": PVC potable water main pipe 4" through 12" shall be manufactured in accordance with AWWA standard C900, latest edition. The PVC pipe shall have a minimum working pressure rating of 150 psi and shall have a dimension ratio (DR) of 18. Pipe shall be the same O.D. as ductile iron pipe and be compatible for use with ductile iron fittings. PVC potable water main pipe shall be solid blue in color. White pipe is strictly prohibited. All PVC pipe shall bear the approved seal of the National Sanitation Foundation (NSF) that will remain legible during normal handling, storage and installation.

Polyethylene potable water service pipe: Pipe shall be High Density polyethylene (HDPE) as per AWWA C906. Carrier: HDPE pipe shall be DR 11, working pressure rating of 160 psi.