

# REQUEST FOR QUOTATION

RFQ-11-46

CITY OF WINTER HAVEN  
" An Equal Opportunity Employer"

Please return quote to:  
City of Winter Haven  
Procurement Service Division  
401 6th St SW  
Winter Haven, FL 33880

For additional information and clarification contact:  
Department Name: Utility Services

Telephone #:

Bert DiBiasie  
Whitey Walling  
863-291-5853

DATE ISSUED: 4/8/2011

Please quote on the following items:

Item	Quantity	Description	Unit Cost	Total Cost
A	800'	10" C900 DR18 Blue Water Pipe	\$	\$
B	440'	10" HDPE DR11 Blue Stripe Pipe	\$	\$
		<i>See specifications attached</i>		
		Total, Items A-B		\$

**Prices must be valid for 90 days.**

Procurement Services Division Director: \_\_\_\_\_

DELIVERY WANTED: Within 2 weeks

We offer to sell you as above F.O.B., Winter Haven, Florida. Delivery can be made in \_\_\_\_\_ days from receipt of order.

**Quotation must be received NO LATER THAN 2:00 P.M., 04/21/11**

**to: Procurement Services Division, address above or FAX TO 863-291-5666**

SIGNATURE: \_\_\_\_\_

DATE: \_\_\_\_\_

\*\*COMPANY NAME: \_\_\_\_\_

ADDRESS: \_\_\_\_\_

CITY/STATE: \_\_\_\_\_

PHONE: \_\_\_\_\_

FAX: \_\_\_\_\_

EMAIL: \_\_\_\_\_

**\*\*PAYMENT WILL BE RENDERED TO THE NAME AND ID APPEARING ON THE W-9.**

## SPECIFICATIONS

PVC potable water main pipe 4" through 12": PVC potable water main pipe 4" through 12" shall be manufactured in accordance with AWWA standard C900, latest edition. The PVC pipe shall have a minimum working pressure rating of 150 psi and shall have a dimension ration (DR) of 18. Pipe shall be the same O.D. as ductile iron pipe and be compatible for use with ductile iron fittings. PVC potable water main pipe shall be solid blue in color. White pipe is strictly prohibited. All PVC pipe shall bear the approved seal of the National Sanitation Foundation (NSF) that will remain legible during normal handling, storage and installation.

Polyethylene potable water service pipe: Pipe shall be High Density polyethylene (HDPE) as per AWWA C906. Carrier: HDPE pipe shall be DR 11, working pressure rating of 160 psi. The following are approved pipe manufacturers:

- (a) CRS, PolyPipe PE 3408, 4" to 24" diameter
- (b) PLEXCO PE 3408, 4" to 24" diameter