

REQUEST FOR QUOTATION

CITY OF WINTER HAVEN

" An Equal Opportunity Employer"

RFQ-11-63

Please return quote to:

City of Winter Haven
Procurement Service Division
401 6th St SW
Winter Haven, FL 33880

For additional information and clarification contact:

Department Name: Utility Services

Bert DiBiasie

Telephone #: 863-291-5853

DATE ISSUED:

6/1/2011

Please quote on the following items:

Item	Quantity	Description	Unit Cost	Total Cost
A	2000 feet	8" DR18 C900 Blue Water Pipe	\$	\$
B	20 each	8" x 1" Tapping Saddle w/SS straps for 9.05 O.D.	\$	\$
C	20 each	1" Curb Stops Ford #B84-444W or equal	\$	\$
Total (Items A - C)				\$
Items A - C must comply with the attached specifications				

Prices must be valid for 90 days.

Procurement Services Division Director: 

DELIVERY WANTED 14 days after acceptance of quote

We offer to sell you as above F.O.B., Winter Haven, Florida. Delivery can be made in _____ days from receipt of order.

Quotation must be received NO LATER THAN 2:00 P.M., June 10, 2011

at: Procurement Services Division, address above or FAX TO 863-291-5666

SIGNATURE: _____

DATE: _____

**COMPANY NAME: _____

ADDRESS: _____

CITY/STATE: _____

PHONE: _____

FAX: _____

EMAIL: _____

****PAYMENT WILL BE RENDERED TO THE NAME AND ID APPEARING ON THE W-9.**

SPECIFICATIONS (03/03/11)

RFQ-11-63

PVC potable water main pipe 4" through 12": PVC potable water main pipe 4" through 12" shall be manufactured in accordance with AWWA standard C900, latest edition. The PVC pipe shall have a minimum working pressure rating of 150 psi and shall have a dimension ration (DR) of 18. Pipe shall be the same O.D. as ductile iron pipe and be compatible for use with ductile iron fittings. PVC potable water main pipe shall be solid blue in color. White pipe is strictly prohibited. All PVC pipe shall bear the approved seal of the National Sanitation Foundation (NSF) that will remain legible during normal handling, storage and installation.

Curb Stops: The curb stops shall be ball valve, roundway, with deck, with lock wing cast on stop body and operating tee cap to provide for locking the stop in closed position. Curb stops shall be threaded in accordance with specifications in AWWA C900 and AWWA C901. All curb stops must be pack joint fittings (no compression).

Service Saddles: Service saddles shall have a body made of stainless steel or ductile iron coated with fusion epoxy or nylon, be equipped with stainless steel double tie straps, and be suitable for either wet or dry installation. The saddle shall be anchored by a minimum four (4) stainless steel bolt pattern on a ductile iron saddle body. The sealing gasket shall be the O-ring type suitable for the applicable service. Outlet flange shall be ANSI B16.1, 125 lbs. standard. Tie straps and bolts shall be a corrosion resistant alloy steel.