

**Combined Sewer Overflow ( CSO ) Monitoring**

Event Date: 1/23/19 - 1/25/19

**Cline Street ( 003 )**

**Collector Information**

Start Time: 1/23/19 ~1230  
 End Time: 1/25/19 ~0730  
 Max. water depth over weir ( inches ) 8"

Sample Time: 0730 Samplers: JO KA

Total Suspended Solids (00530) 63.0 mg/L  
 CBOD 5 Day (80082 ) 16.5 mg/L

Duration of discharge ( hours ) ~48

Flow ( MG ) ( 50050 ) 3.59

Rainfall assc. With event ( inches ) 0.54

Duration of Rain Event (hours) ~14

**Washington Street ( 004 )**

**Collector Information**

Start Time: 1/23/19 ~1625  
 End Time: 1/25/19 ~0740  
 Max. water depth over weir ( inches ) 5"

Sample Time: 0740 Samplers: JO KA

Total Suspended Solids (00530) 45.3 mg/L  
 CBOD 5 Day (80082 ) 102 mg/L

Duration of discharge ( hours ) ~48

Flow ( MG ) ( 50050 ) 2.39

Rainfall assc. With event ( inches ) 0.54

Duration of Rain Event (hours) ~14

**Plant Bypass ( 009 )**

**Collector Information**

Start Time: \_\_\_\_\_  
 End Time: \_\_\_\_\_  
 Water depth over weir ( inches ) \_\_\_\_\_

Sample Time: N/A Samplers: N/A

Total Suspended Solids (00530) \_\_\_\_\_  
 CBOD 5 Day (80082 ) \_\_\_\_\_

Duration of discharge ( hours ) \_\_\_\_\_

Flow ( MGD ) (50050 ) \_\_\_\_\_

Rainfall assc. With event ( inches ) \_\_\_\_\_

Duration of Rain Event (hours) \_\_\_\_\_

Complete the following Items within 4 hours of event discovery

	Call the Huron Co Health Department 419-668-1652 Ext 239
	Email Environmental environmental@huroncohealth.com
	Email Lisa Hivnor cityofnorwalk@norwalkoh.com

Notes: There was a considerable amount of melting snow associated with this overflow, as well. Updated on 2/1/19.

Wade Leimeister  
 City of Norwalk WWTP  
 Superintendent  
 419-663-6755



